




## Smoke and Dye-Water Observation Summary

### Western Run Pilot Project - Baltimore Maryland

#### FIELD SKETCH



Sketch No: 100

#### Filename Path:

X:\Baltimore City\Western Run Pilot Area - Data Files\Smoke Testing\Pictures\Sketches\100.tif

Image Status: Image found and displayed.

NOTE: Sanitary sewer alignments and connectivity in the Western Run GIS have been revised following smoke testing to reflect updated information from various sources and may no longer match the field sketches shown.

# DYE TESTING FORM

Sketch (NTS)  
Dye Test 100

MH 13YY1-011

Show North Arrow

CROSS COUNTRY  
BLVD.

ALLEY

plug

Dye Flooded this  
Catch Basin

Defect B2

KEN OAK  
Rd.

From  
0691518

RESULT CODES		SOURCE TYPE NOTES		
1. POSITIVE	1. MAIN SEWER	5. DOWN SPOUT	9. STAIRWELL DRAI	13. STORM DRAIN
2. NEGATIVE	2. SERVICE LINE	6. DWNSTPT CONN.	10. FOUNDATION DRAIN	14. CATCH BASIN
3. CANNOT TEST	3. TRANSITION JOIN	7. AREA DRAIN	11. BUILDING INTERIOR	15. STORM MH
	4. CLEAN OUT	8. DRIVEWAY DRAIN	12. MH FRAME/SEAL	16. STORM DITCH

Additional Comments: \* THERE IS A SEPRATE STORM LINE THAT  
RUNS DOWN NEXT TO THE SANITARY & SHARES  
M.H. 069148L, DYE UBAINED INTO IT BUT NOT THE  
SANITARY SEWER. RKR